



Product Service

CERTIFICATE

No. B 06 06 58029 001

**Holder of Certificate: ASSA ABLOY
Entrance Systems AB**Lodjursgatan 10
261 22 Landskrona
SWEDEN**Production
Facility(ies):**

10258, 48861

Certification Mark:**Product:****Sliding door movement
(Automatic sliding doors for escape
routes)****Model(s):****Besam UniSlide (T) Single
Besam UniSlide (T) Double
Besam UniSlide ADS****Parameters:**

rated voltage:	100 - 240 V AC 50/60 Hz
rated current:	1 A
type of protection:	I
degree of protection:	IP 20
No. leaves:	1 2 4
leaf weight:	200 kg 100 kg 80 kg
remark:	Without rubber cord or without break out the door cannot be used in escape routes. Different options are described by constructional data form.

Tested according to:AutSchR:1997
EN 60335-1/A11:2004
DIN 18650-1:2005
DIN 18650-2:2005
BGR 232:2003

The product was tested on a voluntary basis and complies with the following essential requirements. The certification mark shown above can be affixed on the product. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

71308366

Date, 2006-07-24
Page 1 of 1