



Certificate of Compliance

INDICATING VALVES – Butterfly Type

This certificate is issued for the following equipment:

MODEL 20W92 AND MODEL 20L92
Sizes 2, 2½, 3, 4, 5, 6, 8, 10, 12 inch NPS
(50, 65, 80, 100, 125, 150, 200, 250, 300 mm DN)
Rated Working Pressure 232 psi (16 bar, 1600 kPa),
with and without dual supervisory switches

Manufactured by:

TTV, S.A.
Severo Ochoa, 11
28914-LEGANES (Madrid) ESPAÑA
SPAIN

FM Approvals confirms that the equipment has been found to comply with the following standard:

FM Approvals Standard Class Number 1112
“Indicating Valves - Butterfly or Ball Type”
August 2006

Project Identifier:


3025174


Date of Approval:

June 17, 2008



Member of the FM Global Group


Richard B. Dunne
Manager-Hydraulics Group


Date